

Attn : Supervisors Office Fax 795-2031

Marlborough Wastewater
Water Quality Management, Inc.
P.O. Box 733
Marlboro, NY 12542
845 236-7824

Al Lanzetta, Town Supervisor
Town of Marlborough
P.O. Box 305
Milton, NY 12547

RE: Bayside Development Project

November 22, 2017


Dear Mr. Lanzetta,

I have done an abbreviated review of the Preliminary site (Utility Profile and Detail) plan for Bayside Development Project (Tax Lot 109.1-4-29).

In my opinion, everything shown seems to be properly designed. There does not appear to be adequate details of the 9W crossing of the sewer line and it's connection into the manhole at 9W and Young Ave.

Do to the complex nature of these drawings and details, I would defer to a Town appointed licensed professional Engineer for a detailed review of these plans and specs before final approval.

Sincerely,



Tony Falco
Water Quality Management, Inc.